

AUTHORIZATION TO MARK

Date: 5/7/98

ARG/ljm

This authorizes the manufacturer to apply the ETL mark to certified products when made in accordance with the accompanying descriptions and drawings under the conditions set forth in the Certification Agreement herein:

Applicant: Windrock, Inc.
431 Park Village Drive
Knoxville, TN 37923

Contact: Ed Flanagan, 423/539-5944 phone, 423/675-3100

Manufacturer: Same as Applicant

Reference Report: 198*13064-001

Product Covered: Pressure Transmitter for Use in Class I, Groups A,B,C,D Hazardous Locations; model A6082E

Description: Electronic device that converts the output of a strain gauge pressure sensor to the industry standard 4-20mA signal. The electronics are packaged on a printed circuit board housed within a stainless steel enclosure. A 6-pin connector is provided for connections to the equipment. For Division I applications, the product must be powered from a Listed Intrinsically Safe Barrier per the control drawing.

Standard(s): Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, III, Division 1, Hazardous (Classified) Locations (UL 913, 5th Ed.) Standard for Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations (UL 1604, 3rd Ed.).

This procedure, with all revisions, etc., is the property of Intertek Testing Services and is intended solely for the guidance of the listee and the representative of Intertek Testing Services, and is not transferable.

Issued by: Intertek Testing Services NA Inc., 24 Grafton Avenue, Cortland, NY 13045-2014 USA



Authorized by:

William T. Starr
William T. Starr *WTS*
Certification Manager

Date: *May 18, 1998*