

AUTHORIZATION TO MARK

This authorizes the manufacturer to apply the ETL mark to certified products; also to the multiple listee model numbers as listed on the correlation page of the Listing Report where applicable; when made in accordance with the accompanying descriptions and drawings under the conditions set forth in the Certification Agreement herein:

Applicant: Windrock, Inc.
431 Park Village Dr.
Knoxville, TN 37923

Contact: Mr. Ed Flannagan
Phone: 423-539-5944 Fax: 423-531-6470

Manufacturer: Same as applicant

Reference Report: J20001235-001

Product Covered: Barrier/Interface, Models: 3350 (V-Guard), 3300 (C-Guard)

Description: The products covered by this report are Barrier/Interface units. The units are non-incendive intended to be located in a Class I, Division 2, Group A, B, C, or D location. The units are also Intrinsically Safe Associated Apparatus intended to connect to devices located in a Class I, Division 1, Group A, B, C, or D location. The units consist of a group of dedicated sensor output barriers which connect to intrinsically safe sensors, and interface circuitry which connects to circuits located in a non-hazardous location. The units are intended to be installed in accordance with their respective control drawings, and the NEC.

Standard(s): Intrinsically Safe and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations – UL 913
Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations – CAN/CSA C22.2 No. 157-92
Electrical Equipment for Use in Class I and Class II, Division 2, and Class III Hazardous (Classified) Locations – UL 1604
Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations – CSA C22.2 No. 213-M1987

This procedure, with all revisions, etc., is the property of Intertek Testing Services and is intended solely for the guidance of the listee and the representative of Intertek Testing Services, and is not transferable.

Issued by: Intertek Testing Services NA Inc., 24 Groton Avenue, Cortland, NY 13045-2014 USA

Authorized by:

William T. Starr
William T. Starr
Certification Manager

Date:

April 3, 2000

Control No.: 94308

